



**NOTES:**

1. REMOVE JUMPER JA TO PREVENT HANDSWITCH INITIATED MOTION
2. J1 AND J2 ARE REQUIRED AS SHOWN
3. 240VAC ALARM AVAILABLE BETWEEN TERMINALS B AND E.

SIZE:  
**A**

17-7000-750 -

THIS DOCUMENT IS A COPY AND IS NOT THE SOURCE DOCUMENT. INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTICE. THE INFORMATION CONTAINED HEREIN IS COPYRIGHTED BY HAROLD BECK AND SONS, INC. CHANGES TO THE DOCUMENT ARE PROHIBITED. CONTACT A BECK SALES ENGINEER IF A CERTIFIED DRAWING IS REQUIRED.

## HAROLD BECK & SONS INC

NEWTOWN INDUSTRIAL COMMONS NEWTOWN, PENNSYLVANIA 18940 USA

TITLE:  
**WIRING DIAGRAM GROUP 11-1X9/2X9/3X9/409/419/469**  
**240 VOLT FUSED 2 AUX SWITCHES INT CPS**  
**W/ HART/LOCAL DCM**

DRAWN:  
GMD 9/30/10

SCALE:  
NONE

DRAWING NO:

REV:

CHECKED:  
DWK 10/5/10

**17-7000-750**

-

APPROVED:  
HHS 10/6/10

SHEET NO. 1 OF 1